To: Dianne Spriggs, EEO Program

Manager, WASO

Company: United States Department of Interior

Phone: 202-354-1852 Fax: 202-371-2264

From: BRIAN H. OUZOUNIAN

2821 Dumfries Road, Los Angeles, CA 90064-4412

Phone: 310-838-3571 Fax: 310-838-8594

Date: 7-16-06

Pages including this cover page: 2

Comments concerning Memo P4217 (Yose-PM):

Ms. Spriggs: I am in receipt of a copy of the above memo from Superintendent Tollefson (attached) and I have the following comments:

- a. Far more exists at restroom #0420 than illustrated both interior and exterior. Traps are not wrapped. Hooks are not accessible. Potable water not accessible via standard ramps or slabs
- b. The other three restrooms in North Pines are substandard per my site walk with Larry Harris and Bill Delaney in July of 2005, without exception, contrary to the superintendent's contentions.
- c. Re: Restroom 420, the hooks installed and the floor tile filling were done but substandard. The hooks are not institutional grade and not the same finish as the bathroom [plated brass v. chrome or stainless steel. No hooks exist for the disabled.] The holes were filled but the lead shields/anchors were not first drilled out, disinfected and filled with mortar. Unsanitary residue/bacteria from years of neglect still surround the holes in the floor and need to be scrapped and disinfected. The floors need to be high pressure washed in their entirety as well.
- d. I wish to meet any representative on site anytime during August 7-13th. My cell phone is 310-466-7960. I recently tried to contact Mr. Harris after the 4th of July, in the Valley, but he was out with a death in the family. I left a message at his office in Mariposa.